



TEST REPORT NO 182/1/LB/2018

SUBJECT OF TESTING: FLOAT GLASS

ORDERER: PRESS GLASS S.A.

NOWA WIEŚ

UL. KOPALNIANA 9

42-262 POCZESNA

DATE OF RECEIPT THE SAMPLES: 19.09.2018 r.

DATE OF TESTS: 27-28.09.2018 r.

**EXECUTOR: technik Jacek Kamiński
mgr inż. Marcin Pożarowszczyk**

Number of copies: 1

Number of pages: 3

Warsaw, 03.10.2018

RESEARCH LABORATORY ICiMB/OCiB	TEST REPORT NO 182/1/LB/2018	page 2 / 3
---	---	------------

1. Subject of testing

Sample of the glass described as:

Float half-hardened with screen print, dimensions 500 x 1000 x 8 mm

Producer: PRESS GLASS O/TYCHY

UL. CIELMICKA 44

43-100 TYCHY

Number of sample: 2 pieces

Designation of sample: WL/IV/P/130/2018

The samples taken and delivered to the Research Laboratory by the Orderer.

2. Scope of tests and the place of their execution.

- determination of critical slip angle

Scope of tests has been established by the Customer.

Tests have been made in the Research Laboratory of Ceramics and Concrete Division,
ul. Postępu 9, 02-676 Warsaw

3. Testing methods:

DIN 51130:2014-02

Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test.

4. Results of tests

4.1. Determination of critical slip angle.

According to DIN 51130:2014-02 Testing of floor coverings. Determination of the anti-slip properties. Workrooms and fields of activities with slip danger, walking method. Ramp test.

Sample size: 0,5 m²

RESEARCH LABORATORY ICiMB/OCiB	TEST REPORT NO 182/1/LB/2018	page 3 / 3
-----------------------------------	---------------------------------	------------


Critical slip angle	
Adjusted average overall acceptable angle α_{ges}	Anti-slip properties class
6,1	R 9

5.0. Statement.

5.1. Results of tests relate exclusively to tested objects.

5.2. Test report may be copied only as a whole, whereas for partial copying the consent of laboratory is required.

The person responsible for the report:


Agnieszka Ducka, M Sc

The person authorizing the report:

Kierownik
Laboratorium Badawcze
Oddziału Ceramiki i Betonów

mgr Agnieszka Ducka