

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-CA7015

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Insulating Glazing Units incorporating AGC Pyrobel and Pyrobelite glasses, produced and placed on the market by Press Glass

Intended use: Insulating Glass units and Laminated Glass and Laminated safety glass to be used in buildings and construction works

Product	Fire Resistance Classification	Fire Resistance Classification report(s)*	Reaction to fire Classification
Vertical installations			
Pyrobelite 7	EW30	WF 162123	A2-s1,d0
Pyrobelite 13	EW30	WF 162123	A2-s1,d0
Pyrobelite 12	EI20/EW60	WF 157797	A2-s1,d0
Pyrobel 8	EI15/EW30	PK2-05-06-011-A-0	A2-s1,d0
Pyrobel 16	EI30/EW60	12341B	A2-s1,d0
	EI30	12277B	
Pyrobel 17	EI45	PKO-06-070/AO 204	A2-s1,d0
Pyrobel 17N	EW60	WF 13931B	A2-s1,d0
	EI45/EW60	WF 14263B	A2-s1,d0
Pyrobel 21	EI45/EW60	163749	A2-s1,d0
Pyrobel 23	EI60	10V522	A2-s1,d0
Pyrobel 23 EG	EI60	10V522	A2-s1,d0
Pyrobel 25	EI60	05G309A	A2-s1,d0
Pyrobel 35	EI90	05V274	NPD
Pyrobel 53	EI120	06V074	NPD
Pyrobelite 7 EG/ Pyrobelite 11	EW30	13238B	NPD
Pyrobelite 12 EG	EI20/EW60	162206	NPD
Pyrobel 8 EG	EI15/EW30		NPD
Pyrobel 16 EG	EI30/EW60		NPD
Pyrobel 17 EG	EI45		NPD
Pyrobel 17 N EG	EW60	WF 13931B	NPD
	EI45/EW60	WF 14263B	NPD
Pyrobel 21 EG	EI45/EW60	163749	NPD
Pyrobel 25 EG	EI60	05V065	NPD
Pyrobel 30	EI90	10V433	NPD
Pyrobel 30 EG	EI90		NPD
Pyrobel 30 DGU	EI90		NPD
Pyrobel 35 EG	EI90	162206	NPD
Pyrobel 53 EG	EI120		NPD
Pyrobel 53 N	EI120	14654B	NPD
Pyrobel 53 N EG	EI120		NPD
Horizontal installations			
Pyrobel 19H	EI30	PK20305004A1	NPD
Pyrobel 23H	EI45	PK20304004A1	NPD
Pyrobel 28H	EI60	PK20305005A1	NPD

*Classification reports (available on request from the glass manufacturer) defines fire resistance classification and is dependent on framing system and glazing configuration. The classification reports which determine the above EN13501-2 classifications detail the precise field of application for fire resisting applications within the scope of UKCA marking. Additional 'market application' tests or extended application reports may also be appropriate for use with UKCA marked glasses.

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-CA7015

Placed on the market under the name of

**Press Glass Sp. z o.o.
ul. Golfowa 19
42-274 Konopiska
Poland**

and produced in the manufacturing plant

V/011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 14449: 2005 / EN 1279-5: 2018

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **04/02/2022** and re-issued on **17/07/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **03/02/2025**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**